

Tender Questions & Answers

FROM: DRC-YEMEN

Tender No: ITB-YEM-1610NOR2023-WASH-LATRINES

Tender Title: **Household Latrines in Two Sites in Yemen, North Area Hajjah and Hodeidah as below**
A:Ahem Subdistrict, Kushar District, Hajjah Gov; B: Al-Ramya Al-Olya and Al-Ramya Al-Sufila, As-Sukhnah District, Hodeida Gov.

Tender Issuing Date: 27-Oct-2023

Tender Closing Date: 19-Nov-2023

Danish Refugee Council-DRC Yemen has in reference to above tender period received the following questions to the Tender, and hereby provides responsive answers by best endeavour to all relevant Vendors & Suppliers.

Answers/Clarifications الاجوبة والتوضيحات		Questions/Answers الاسئلة والاستفسارات		
The description of items No.2 and 3 were mistaken and the correct description will be according to the below.		Regarding the items, No2 and 3 they are similar in both HHs and PWD latrines, and the design is different, is there a copy paste mistake or you want it like that?		
Item No	Description	الوصف	UoM الوحدة	Quantity الكمية
2	Supply and building of foundation under the slab of pit, by automatic concrete blocks with size of 20*20*40cm using cement morater with mixing ratio 1:3, with 10cm layer of crushed stone under the block walls, according to drawings, specifications, and instructions of the supervisor engineer.	أعمال مباني بلك اوتوماتيك (صم) 40*20*20 سم للجدران اسفل غطاء البيارة باستخدام مونه اسمنتية بنسبة خلط [3:1] اسمنت الى نيس مع عمل طبقة من الجعم اسفل الجدران مع التعبئة الجيدة للبناء وعمل جميع ما يلزم لإنهاء العمل على أكمل وجه حسب الرسومات والمواصفات وتوجيهات المهندس المشرف	M2 م2	2.16
3	Supply and cast 2 reinforced concrete slab B350 kg/m3, for the pit with cover,size (0.75 m × 1.50 m × 10 cm thickness), including reinforcement (6 Φ 10mm/m bottom & 6 Φ 10 top)m, including 2 handles 20cm, embedded into the cover, with diameter of 10mm steel bars.	عمل عدد 2 غطاء خرساني لفتحة البيارة بسمكة 10 سم وابعاد 1.50 * 0.75 م وحديد تسليح 6 Ø10 م فرش و 6 Ø10 م غطاء والعمل يشمل عمل ممسك حامل للغطاء من الجهتين بشكل نصف دائرة يثبت قبل صب مع حديد التسليح لغطاء البيارة من الحديد ابو 10 مم بطول 20 سم	M3 م3	0.26